

CLIMATIX MANUAL


Table of contents

1	User guide	2
1.1	Connecting to user profile.....	2
1.2	Chiller start up	3
1.3	Temperature setpoint	3
1.4	Alarm acknowledge	3
2	Service guide	3
2.1	Connecting to service profile	3
2.2	Menu map	5
2.3	BSP and BUS led meaning	13
3.	Alarm list	14
3	Modbus RTU list	16
4	BACnet.....	27

1 User guide


1.1 Connecting to user profile

Connect to „User“ profile. Hold „Enter“ button for 3 seconds.



1. Pic. Button placement

After 3 seconds screen changes to Pic. 2.



2. Pic. Login screen

User password is 1000 and it can be entered by “Up” and “Down” buttons and confirm selection press „Enter“. When correct password is entered in the right corner one key icon will be showed.

1.2 Chiller start up


To start up the system user must change “Unit status On/Off” from “Off” -> “On” and check if “Remote On/Off” status is “On”.

1.3 Temperature setpoint

Chiller will work unit it reaches setpoint. To change setpoint find parameter “Cooing setpoint” press „Enter“ and change do the desired temperature confirm with „Enter“.

1.4 Alarm acknowledge

All alarms are listed in the history. To see active alarms and accrued alarms press „Alarm“ button, if there are active alarms firstly they will be showed and „Alarm“ button will blink red. By pressing button „Alarm“ for couple of time screen to change to history.




3. Pic. Alarm list

To acknowledge alarm select „Acknowledge“ and press „Enter“ press „Execute“. All alarm will be reseted if conditions are right all other will be left in alarm conditions.

2 Service guide


2.1 Connecting to service profile

Connect to „Service“ profile. Hold „Enter“ button for 3 seconds.



4. Pic. Button placement

After 3 seconds screen changes to Pic. 6.



5. Pic. Login screen

User password is 2000 and it can be entered by "Up" and "Down" buttons and confirm selection press „Enter“. When correct password is entered in the right corner two key icon will be showed.

2.2 Menu map

Menu map			
	Main menu	Sub Menu	
I	Supply control ➡	1	Settings
II	Capacity control ➡	1	Settings
III	Circuit control ➡	1	Settings
¹ IV	Scheduler ➡	1	Scheduler settings
V	System ➡ ➡ ➡ ➡ ➡ ➡ ➡ ➡ ➡ ➡ ➡	1	Communications 2 Plant info 3 Versions 4 Save / load 5 Archive 6 System alarms 7 Diagnostic 8 Alarming 9 PIN handling 10 Daylight sav.time 11 HMI
VI	Overviews ➡ ➡ ➡ ➡ ➡ ➡ ➡	1	Operating hours 2 Controller inputs 3 Controller outputs 4 Expansion inputs 5 Expansion outputs 6 Analog inputs alarms 7 Digital inputs alarms
VII	Main overview		

1 – Active when scheduler function is enabled.

I. Supply control

Operating mode	Actual operation mode
Flow detector	Status of flow detector single pump
Evap. out t.	
Evap. in t.	
Settings	Settings of the pumps

I.1. Supply control settings

St-up del. flow	Delay flow alarm after evaporator pump start
¹ Pump cond. flow det. delay st-up	Delay flow alarm after condenser pump start
St-up dly. comp.	Delay compressor start after pump start
² Pumps rotation time	Rotation time between twin pumps
² Pump control mode	Control more of twin pump
Frost protection	Frost protection pump setpoint
Hyst. frost protection	Frost protection hysteresis for alarm reset user pump
Frost prot. warning	Frost protection warning pump setpoint
Hyst. frost prot. war.	Frost protection warning hysteresis for alarm reset pump
² Cond. r.t. setpoint	Condenser valve setpoint of return cond. temp.
² Cond. r.t. dif to close	Condenser valve difference to close valve
Warn. frost prot.	Frost protection warning pump alarm
Frost protection	Frost protection pump alarm

1 – Active when water condenser is enabled.

2 – Active when twin pump is enabled.

II. Capacity control menu.

Operating mode	Working mode
Com.op.mode	Common working mode
Control request	Current power request
Present request	Current power request
Evap. in t.	
Cooling setpoint	Cooling setpoint
Evap. out t.	
Settings	

II1. Capacity control settings.

Cooling setpoint	Cooling setpoint
Kp	P value for PID control
Ti	I value for PID control
Faster power dec. For Kp	When setpoint reached faster shutdown power

III. Circuit manager.

Operating mode	Common working mode
Next circuit On	Next circuit which will be turned on
Next circuit Off	Next circuit which will be turned off
Settings	Settings

III.1. Circuit manager settings.

Capacity step regulation delay	Capacity change delay for up/down power operations
--------------------------------	--

IV. Scheduler

Enable scheduler	Turn off/on scheduler
01: Monday	Monday settings
01: Tuesday	Tuesday settings
01: Wednesday	Wednesday settings
01: Thursday	Thursday settings
01: Friday	Friday settings
01: Saturday	Saturday settings
01: Sunday	Sunday settings
01: Exception	Exception settings

V. System.

Current time	Time adjustment
Date /Time settings	Time adjustment
Restart	Controller restart
Communications	Communication controller settings
Plant info	
Versions	
Save / load	Save parameters to sd card
Archive	Archive and save to sd card
Sistem alarms	System alarms
Diagnostic	Controller diagnostic
Alarming	Alarm page
PIN handling	Pin code change
Daylight sav.time	Daylight time saver settings
HMI	Display parameters settings
Language selection	Currently only english

V.1 System communications.

Comm.modue overview	Comunication module overview
Communic.config.	Comunication config (Modbus slave RS485, TCP/IP, Bacnet RS485/ IP)
IP-Config	IP config
>	IP
>	Unique controller name
WLAN	WIFI stick settings
>	IP WIFI stick
Modbus RTU (RS485)	Modbus parameters
Climatix IC	Cloud parameters
BACnet	BACnet settings
Process bus	Process bus settings

VI. Overviews.

Operating hours	Operating hours of the aggregates
Controller inputs	Controller real input status
Controller outputs	Controller real outputs status
Expansion inputs	Expansion real input status
Expansion outputs	Expansion real outputs status
Expansion inputs 2	Expansion 2 real input status
Expansion outputs 2	Expansion 2 real outputs status

VII. Main overview.

Machine status	Common operating mode
Present request	Power request
¹ Total power master	Total power with master/slave unit, only visible in master
Present capacity	Real power
Evap. out t.	Evaporator outlet temperature
¹ Evap. common out t.	Common temp. only in master
² Circuit 1 Evap. out t.	Circuit 1 evaporator outlet temp.
² Circuit 2 Evap. out t.	Circuit 2 evaporator outlet temp.
² Circuit 3 Evap. out t.	Circuit 3 evaporator outlet temp.
Evap in t.	Evaporator inlet temperature
⁴ Cond. in t.	Condenser inlet temperature
⁴ Cond. out t.	Condenser outlet temperature
Control temp.	Control temperature Evap in t. / Evap. out t.
Cooling setpoint	Cooling setpoint
Supply pump	Single pump status
³ Supply pump 1	Twin pump 1 status
³ Supply pump 2	Twin pump 2 status
Flow det.	Single pump flow detector
³ Flow det.	Twin pump flow detector
⁴ Cond. flow det.	Condenser flow detector
Circuit 1	Circuit one parameters
Evap. press.	
Cond. press.	
Circuit 2	Circuit two parameters
Evap. press.	
Cond. press.	
⁵ Circuit 3	Circuit three parameters
⁵ Evap. press.	
⁵ Cond. press.	
⁶ Free Cooling	Free Cooling parameters
⁷ Outdoor temp.	
Unit On/Off	Display on/off
Remote On/Off	DI on/off
⁸ Scheduler status	Status of the scheduler in real time
Emergency mode	Then emergency on plant is shut off
Main menu	

- 1 – Active when Master/Slave is enabled.
- 2 – Active when evaporators is separate.
- 3 – Active when twin pump is enabled.
- 4 – Active when water condenser is enabled.
- 5 – Active when circuit 3 is enabled.
- 6 – Active when free cooling is enabled.
- 7 – Active when free cooling or outside temp. or floating condensation is enabled.
- 8 – Active when scheduler function is enabled.

Circuit 1,2,3 menu

Evap.press.	Evaporator pressure
Evaporator temp.	Temperature converted from pressure
Cond.press.	Condenser pressure
Condenser temp.	Temperature converted from pressure
Compressor1	Compressor 1 status
¹ Dcrg. gas temp.	Compressor 1 discharge gas temperature
² Pos. Comp.1	Position of compressor 1 inverter 0-100 power
³ Freq. Comp.1	Frequency of the Vacon inverter readed from inverter
³ Curr. Comp.1	Current of the Vacon inverter readed from inverter
⁴ Freq. Comp.1	Frequency of the ABB inverter readed from inverter
⁴ Curr. Comp.1	Current of the ABB inverter readed from inverter
⁵ Total SH comp.	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
⁶ Compressor2	Compressor 2 status
¹ Dcrg. gas temp.	Compressor 2 discharge gas temperature
⁵ Total SH comp.	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
⁷ Compressor3	Compressor 3 status
¹ Dcrg. gas temp.	Compressor 3 discharge gas temperature
⁵ Total SH comp.	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
⁸ Dcrg. gas temp.	Discharge gas common temperature
Superheat	Real superheat
Exp.valve	Expansion valve position
⁹ MVL	Expansion valve position
⁹ MVL feedback	Expansion valve feedback position
Condenser fan	Fan power
¹⁰ Liquid temp.	Subcooling temperature
Circuit control	Circuit parameters
Compr.manager	Compressors management
Expansion	Expansion control
Condenser	Condenser control

- 1 – Active when separate discharge gas sensors are enabled.
- 2 – Active when compressor with inverter is enabled.

- 3 – Active when compressor with inverter and control via Modbus with Vacon drive are enabled.
- 4 – Active when compressor with inverter and control via Modbus with ABB drive are enabled.
- 5 – Active when additional suction sensor and superheat calculation is enabled.
- 6 – Active when compressor 2 is enabled.
- 7 – Active when compressor 3 is enabled.
- 8 – Active when common discharge gas is enabled.
- 9 – Active when MVL expansion valve is enabled.
- 10 – Active when Subcooling temp. is enabled.


Circuit 1 Circuit control.

Com.op.mode	Common working mode
Settings	Settings

Circuit 1 Circuit control settings.

St-up d.pr.enve.	Start up delay of envelope alarms
Max.High press.	Max. condensing pressure alarm
Min.high press.	Min. condensing pressure alarm
MOP	MOP alarm
LOP	LOP alarm
Presss.ratio max.	Pressure ratio max. alarm
Presss.ratio min.	Pressure ratio min. alarm
Superheat	Superheat

All limits are in absolute pressure.



6. Pic. „Envelop“

Circuit 1 Comp. manager

Operating mode	Common working mode
Next compr.On	Next compressor will be on
Next compr.Off	Next compressor will be off
Settings	Settings

Circuit 1 Comp. manager settings.

Max. Start/h c.	Max. Start of compressor per 1h
Minimal on	Minimal on compressor
Minimal off	Minimal off compressor
Time between same comp. start	Minimal time
¹ Capacity min. for FI comp.	Minimum capacity for frequency inverter
¹ Capacity max. for FI comp.	Maximum capacity for frequency inverter
¹ Cap. st.up comp. 1	Start up compressor 1 power
¹ FI ramp step up size	Frequency inverter ramp up speed
¹ FI ramp step down size	Frequency inverter ramp down speed
¹ FI ramp change delay	Frequency inverter ramp change speed
¹ FI start up time	Frequency inverter stay in minimum power
² ABB Min. freq.	ABB frequency inverter minimum frequency setting
² ABB Max. freq.	ABB frequency inverter maximum frequency setting
Disabled circuit x compressor y	Disabled Circuit x compressor y

1 – Active when compressor with inverter is enabled.

2 – Active when compressor with inverter and control via Modbus with ABB drive are enabled.

Circuit 1 Expansion

Operating mode	Common working mode
Superheat setpoint	Setting for setpoint
Present SH setpoint	Superheat actual setpoint
Superheat	Actual superheat
Evap.press	Evaporator pressure
Evaporator temp.	Temperature converted from pressure
Suct. gas temp.	Suction gas temperature
Exp. valve	Requseted position
Feedb.exp.val.	Real position
¹ Sunction SH. temp.	Additional Suction temperature compressor 1
	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
^{1,2} Total SH comp. 1	
^{1,2} Sunction SH. temp.	Additional Suction temperature compressor 2
	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
^{1,2} Total SH comp. 1	
^{1,3} Sunction SH. temp.	Additional Suction temperature compressor 3
	Superheat callculation bettwen evaporation temp. and Suction SH temp. sensor
^{1,3} Total SH comp. 1	
Settings	Settings

1 – Active when additional suction sensor and superheat calculation is enabled.

2 – Active when compressor 2 is enabled.

3 – Active when compressor 3 is enabled.

Circuit 1 Expansion settings.

Superheat setpoint	Superheat setpoint
Kp	PID P value
Ti	PID I value
Shift enve.	Shift SH setpoint if MOP
Startup position	Start up position
St-up pos.valve	Delay when start up for start up value

Circuit 1 Condenser.

Operating mode	Common working mode
Pres.cooling setpoint	Condenser pressure setpoint display
Pressent setpoint	Actual setpoint
Cond. Press.	
Condenser fan	Condenser power
Settings	Settings

Circuit 1 Condenser settings.

Press. cooling setpoint	Condenser pressure setpoints
Kp Cooling	PID P value
Ti Cooling	PID I value
Shift floating setpoint	Shift condensing setpoint by amount plus outdoor temp.
Shift enve.	Shift envelope
Fan min pwr.	Fan min. power to run

2.3 BSP and BUS led meaning

LED	Color	Flash response	Function
BSP	Red/green	Changes at 1 Hz	Software update mode: Download application or new firmware
	Green	Continuous	Application loaded and operational
	Orange	Continuous	Application loaded but is not operational
	Orange	Flashing, 50 ms on / 1000 ms off	
	Red	Flashing at 2 Hz	Firmware error
	Red	Continuous	Hardware fault
BUS	The application sets the response and functional. Additional notes are available in the SAPRO online help.		

ECV closing and opening LEDs

Status	Open LED	Close LED
Motor not moving in this direction	OFF	OFF
Valve is moving to fail safe position in case of power fail (only for UPS version)	OFF	OFF
Valve is closing	OFF	Green flashing 250ms ON / 250ms OFF
Valve is opening	Green flashing 250ms / ON 250ms OFF	OFF
Valve is moving to the fail safe position closed	OFF	Green short flashing 50ms ON / 450ms OFF
Valve is moving to the fail safe position open	Green short flashing 50ms ON / 450ms OFF	OFF
Stepper error (for example, the diagnostics detected an error at startup, such as not connected or shortened coil)	Green short flashing 50ms ON / 450ms OFF	Green short flashing 50ms ON / 450ms OFF

Additional BSP LED meaning:

BUS (On controller)	BUS
Alarm is not acknowledged	500 ms On / 500 ms Off
Alarm is acknowledged	ON
No Alarm	OFF

3. Alarm list

Water side	Meaning	Stops	Alarm reset
Evap. out t. Fault: no sens.	Probe disconnected	All plant	Manual
Evap. out t. HighLimitActive: 8889 °C	Probe value reached high limit alarm	-	-
Evap. in t. Fault: no sens.	Probe disconnected	All plant	Manual
Evap. in t. HighLimitActive: 8889 °C	Probe value reached high limit alarm	-	-
Fault Supply pump OffNormal: Alarm	Overload pump	All plant	Automatic
Fault Supply pump 1,2 OffNormal: Alarm	Overload pump	All plant	Automatic
Flow det. OffNormal: No	Pump single or twin no flow alarm	All plant	Manual
Warn.frost prot. exchanger	Warning freeze alarm for exchanger	-	Automatic
Frost protection exchanger	Freeze alarm for exchanger pump	All plant	Manual
Warn.frost prot. medium	Warning freeze alarm for medium	-	Automatic
Frost protection medium	Freeze alarm for medium pump	All plant	Manual
Refrigerant side			
Exp. Valve Circuit X Fault: no output	No expansion valve is connected of circuit X	Circuit X	Automatic
Low pr. detect. Circuit X OffNormal: Alarm	Low pressure alarm by digital input, relay of circuit X	Circuit X	Automatic
Low pr. detect. counter Circuit X LowLimitActive: -56 min	Low pressure alarm counter by digital input, relay of circuit X	Circuit X	Manual
High pr. detect. Circuit X OffNormal: Alarm	High pressure alarm by digital input, relay of circuit X	Circuit X	Automatic
High pr. detect. counter Circuit X LowLimitActive: -56 min	High pressure alarm counter by digital input, relay of circuit X	Circuit X	Manual
Fault comp. Y Circuit X OffNormal: Alarm	Overload compressor Y of circuit X	Circuit X Compressor Y	Automatic
Fault comp. Y counter Circuit X LowLimitActive: -56 min	Overload compressor Y of circuit X fault counter for number of 3 times in 1 hour locked alarm	Circuit X Compressor Y	Manual
St-up counter comp. Y Circuit X LowLimitActive: -30min	More compressors start then allowed of circuit X compressor Y	Circuit X Compressor Y	Manual
All compr. In al. Circuit X OffNormal: Alarm	All compressors in circuit X is in alarm/overload	Circuit X	Automatic
No compr.avail. (No compr.avail. Circuit X-OffNormal): Normal	Compressors in circuit X not ready to start because of the timers	Circuit X	Automatic
Suct gas temp. Circuit x OffNormal: Alarm	Probe disconnected	Circuit X	Manual
Suct gas temp. Circuit x HighLimitActive: 8889 °C	Probe value reached high limit alarm of circuit X	Circuit X	Manual
Evap. press. Circuit x OffNormal: op.loop	Probe disconnected	Circuit X	Manual

Evap. press. Circuit x HighLimitActive: 8889 bar	Probe value reached high limit alarm of circuit X	Circuit X	Manual
Cond. press. Circuit x OffNormal: op.loop	Probe disconnected	Circuit X	Manual
Cond. press. Circuit x HighLimitActive: 8889 bar	Probe value reached high limit alarm of circuit X	Circuit X	Manual
Fault Condenser fan Circuit X OffNormal: Alarm	Fan alarm of circuit X	Circuit X	-
Press ratio max. Circuit X OffNormal: Alarm	Pressure difference too high. Compressor is in the upper left side of the envelope of circuit X	Circuit X	Automatic
Press ratio min Circuit X OffNormal: Alarm	Pressure difference too low. Compressor is in the lower right side of the envelope of circuit X	Circuit X	Automatic
Max.high press Circuit X OffNormal: Alarm	To high condensing pressure of circuit X	Circuit X	Automatic
Min.high press Circuit X OffNormal: Alarm	To low condensing pressure of circuit X	Circuit X	Automatic
MOP Circuit X OffNormal: Alarm	MOP alarm of circuit X	Circuit X	Automatic
MOP counter Circuit X OffNormal: Alarm	MOP alarm counter locked alarm of circuit X	Circuit X	Manual
LOP Circuit X OffNormal: Alarm	LOP alarm of circuit X	Circuit X	Automatic
LOP counter Circuit X OffNormal: Alarm	LOP alarm counter locked alarm of circuit X	Circuit X	Manual
Superheat Circuit X LowLimitActive: 2K	Low superheat alarm of circuit X	Circuit X	Automatic
Superheat Fault counter Circuit X LowLimitActive: -30min	Low superheat alarm of circuit X for number of 3 times in 1 hour locked alarm	Circuit X	Manual
Evd comm. Error OffNormal: Alarm	Carel EVD communication alarm	Circuit X	Automatic
Evd alarm Circuit x OffNormal:Alarm	Carel EVD Alam	Circuit X	Automatic
General			
Al.brute force de. (Al.brute force de.-HighLimitActive): 1	Indication that a brute force attack. 1: external HMI (HMI DM/TM)	None	By logining in with good password
Invalid time: Alarm	Alarm that time in controller is wrong	None	By entering right time
Fault Ext.IO-m.Fault Ext.IO-m. (Fault Ext.IO-m.Fault Ext.IO-m.- OffNormal): X	Extension module X is disconnected	Plant	Automatic
Gas leak OffNormal: Alarm	Gas leak alarm	Plant	Automatic

3 Modbus RTU list

Modbus RTU default: Baude rate 19200, parity Even, bit stop One. Modbus TPC/IP default port 502.

Parameter	Address	R/W	Gain	Value
Operation mode				
Common operation mode	H100	R		0 - Off 1 - Cooling
Operation mode HMI	H102	R/W		0 - Off 1 - On
Operation mode Remote On/Off (DI)	H104	R		0 - Off 1 - On
Emergency mode	H106	R		0 - Off 1 - On
Cooling setpoint return	H108	R/W	0.1	
Heating setpoint return	H110	R/W	0.1	
Alarm slave no communication	H144	R		0 - OK 1 - Alarm
Alarm master no communication	H146	R		0 - OK 1 - Alarm
Supply pump paramters				
Evap. out t. temperature value	H200	R	0.1	
Evap. out t. temperature sensor fault	H201	R		0 - OK 1 - Alarm
Evap. in t. temperature value	H202	R	0.1	
Evap. in t. temperature sensor fault	H203	R		0 - OK 1 - Alarm
Common Evap. out t. temp. master slave value	H204	R		
Common Evap. out t. temp. master slave sensor fault	H205	R		0 - OK 1 - Alarm
Single pump status	H206	R		0 - Off 1 - On
Single pump work hours	H207	R		
Supply pump\Twin pump 1 alarm	H208	R		
Twin pump 2 alarm	H209	R		
Twin pump 1 status	H210	R		0 - Off 1 - On
Twin pump 1 work hours	H211	R		
Twin pump 2 status	H212	R		0 - Off 1 - On
Twin pump 2 work hours	H213	R		
Twin pump 1 flow alarm	H214	R		0 - OK 1 - Alarm
Twin pump 2 flow alarm	H215	R		0 - OK 1 - Alarm
Supply pump flow status	H216	R		
Supply pump flow alarm	H217	R		0 - OK 1 - Alarm
Twin pump flow status	H218	R		
Twin pump flow alarm	H219	R		0 - OK 1 - Alarm
Frost waring	H220	R		0 - OK 1 - Alarm
Frost alarm	H221	R		0 - OK 1 - Alarm
Circuit 1 parameters				
Condensing pressure value	H300	R	0.1	
Condensing pressure alarm	H301	R		0 - OK 1 - Alarm
Evaporating pressure value	H302	R	0.1	
Evaporating pressure alarm	H303	R		0 - OK 1 - Alarm
High pressure alarm	H304	R		0 - OK 1 - Alarm
High pressure alarm counter alarm	H305	R		0 - OK 1 - Alarm
Low pressure alarm	H306	R		0 - OK 1 - Alarm
Low pressure alarm counter alarm	H307	R		0 - OK 1 - Alarm
Conensing max pressure	H308	R		0 - OK 1 - Alarm
Conensing min pressure	H309	R		0 - OK 1 - Alarm
MOP alarm	H310	R		0 - OK 1 - Alarm

MOP counter alarm	H311	R		0 - OK 1 - Alarm
LOP alarm	H312	R		0 - OK 1 - Alarm
LOP counter alarm	H313	R		0 - OK 1 - Alarm
Pressure ratio max alarm	H314	R		0 - OK 1 - Alarm
Pressure ratio min alarm	H315	R		0 - OK 1 - Alarm
Evaporating temperature	H316	R	0.1	
Condensing tempertature	H317	R	0.1	
Circuit 1 supply temp. value	H318	R	0.1	
Circuit 1 supply temp. sensor alarm	H319	R		0 - OK 1 - Alarm
Suction temperature value	H320	R	0.1	
Suction temperature sensor fault	H321	R		0 - OK 1 - Alarm
Superheat value	H322	R	0.1	
Superheat alarm	H323	R		0 - OK 1 - Alarm
Superheat alarm counter alarm	H324	R		0 - OK 1 - Alarm
Expansion valve value	H325	R		
Expansion valve alarm	H326	R		0 - OK 1 - Alarm
Circuit 1 frost waring	H327	R		0 - OK 1 - Alarm
Circuit 1 frost alarm	H328	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT104'	H329	R	0.1	
0x2203 'Itf\Pdc.TT104'	H330	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT102'	H331	R	0.1	
0x2203 'Itf\Pdc.TT102'	H332	R		0 - OK 1 - Alarm
Defrost end temp. 1 value	H333	R	0.1	
Defrost end temp. 1 sensor alarm	H334	R		0 - OK 1 - Alarm
Defrost end temp. 2 value	H335	R	0.1	
Defrost end temp. 2 sensor alarm	H336	R		0 - OK 1 - Alarm
Defrost heater	H337	R		0 - Off 1 - On
Reverse valve	H338	R		0 - Off 1 - On
High dicharger gas temp. warning	H339	R		0 - OK 1 - Alarm
High dicharger gas temp. alarm	H340	R		0 - OK 1 - Alarm
Common discharge gas temp.	H341	R	0.1	
Common discharge gas temp. sensor alarm	H342	R		
Low evaporating temp. alarm	H343	R		0 - OK 1 - Alarm
Low evaporating pressure alarm	H344	R		0 - OK 1 - Alarm
High condensing pressure alarm	H345	R		0 - OK 1 - Alarm
No compressor is available alarm	H346	R		0 - OK 1 - Alarm
All compressor in alarm	H347	R		0 - OK 1 - Alarm
Compressor 1 fault	H348	R		0 - OK 1 - Alarm
Compressor 1 possition	H349	R		
Compressor 1 fault counter alarm	H350	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 value	H351	R	0.1	
Discharge temp. comp. 1 alarm	H352	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 alarm	H353	R		0 - OK 1 - Alarm
Suct. temp. comp. 1 value	H354	R	0.1	
Suct. temp. comp. 1 alarm	H355	R		0 - OK 1 - Alarm
Superheat temp. comp. 1 value	H356	R	0.1	
Superheat temp. comp. 1 alarm	H357	R		0 - OK 1 - Alarm
Compressor 2 fault	H358	R		0 - OK 1 - Alarm
Compressor 2 fault counter alarm	H359	R		0 - OK 1 - Alarm

Discharge temp. comp. 2 value	H360	R	0.1	
Discharge temp. comp. 2 alarm	H361	R		0 - OK 1 - Alarm
Discharge temp. comp. 2 alarm	H362	R		0 - OK 1 - Alarm
Suct. temp. comp. 2 value	H363	R	0.1	
Suct. temp. comp. 2 alarm	H364	R		0 - OK 1 - Alarm
Superheat temp. comp. 2 value	H365	R	0.1	
Superheat temp. comp. 2 alarm	H366	R		0 - OK 1 - Alarm
Compressor 3 fault	H367	R		0 - OK 1 - Alarm
Compressor 3 fault counter alarm	H368	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 value	H369	R	0.1	
Discharge temp. comp. 3 alarm	H370	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 alarm	H371	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 value	H372	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 alarm	H373	R	0.1	
Superheat temp. comp. 3 value	H374	R	0.1	
Superheat temp. comp. 3 alarm	H375	R		0 - OK 1 - Alarm
Compressor 1 status	H376	R		1 - Off 2 - On
Compressor 1 work hours	H377	R		
Compressor 1 start up counter alarm	H378	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter alarm	H379	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter feedback alarm	H380	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter comm alarm alarm	H381	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter feedback alarm	H382	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter alarm	H383	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter comm alarm alarm	H384	R		0 - OK 1 - Alarm
Compressor 2 status	H385	R		1 - Off 2 - On
Compressor 2 work hours	H386	R		
Compressor 2 start up counter alarm	H387	R		0 - OK 1 - Alarm
Compressor 3 status	H388	R		1 - Off 2 - On
Compressor 3 work hours	H389	R		
Compressor 2 start up counter alarm	H390	R		0 - OK 1 - Alarm
Condenser position	H391	R		0 - OK 1 - Alarm
Fan overload	H392	R		0 - OK 1 - Alarm
Evap. low temp. alarm counter	H393	R		0 - OK 1 - Alarm
Suction low pressure counter	H394	R		0 - OK 1 - Alarm
Discharge high pressure counter	H395	R		0 - OK 1 - Alarm
Compressor 1 high pressure alarm	H396	R		0 - OK 1 - Alarm
Compressor 1 oil alarm	H397	R		0 - OK 1 - Alarm
Compressor 1 motor overload	H398	R		0 - OK 1 - Alarm
Compressor 1 circuit braker alarm	H399	R		0 - OK 1 - Alarm
Compressor 1 frequency alarm	H400	R		0 - OK 1 - Alarm
Compressor 2 high pressure alarm	H401	R		0 - OK 1 - Alarm
Compressor 2 oil alarm	H402	R		0 - OK 1 - Alarm
Compressor 2 motor overload	H403	R		0 - OK 1 - Alarm
Compressor 2 circuit braker alarm	H404	R		0 - OK 1 - Alarm
Compressor 3 high pressure alarm	H405	R		0 - OK 1 - Alarm
Compressor 3 oil alarm	H406	R		0 - OK 1 - Alarm
Compressor 3 motor overload	H407	R		0 - OK 1 - Alarm

Compressor 3 circuit braker alarm	H408	R		0 - OK 1 - Alarm
Modbus fan 1 alarm	H409	R		0 - OK 1 - Alarm
Modbus fan 1 communication alarm	H410	R		0 - OK 1 - Alarm
Modbus fan 2 alarm	H411	R		0 - OK 1 - Alarm
Modbus fan 2 communication alarm	H412	R		0 - OK 1 - Alarm
Modbus fan 3 alarm	H413	R		0 - OK 1 - Alarm
Modbus fan 3 communication alarm	H414	R		0 - OK 1 - Alarm
Modbus fan 4 alarm	H415	R		0 - OK 1 - Alarm
Modbus fan 4 communication alarm	H416	R		0 - OK 1 - Alarm
Modbus fan 5 alarm	H417	R		0 - OK 1 - Alarm
Modbus fan 5 communication alarm	H418	R		0 - OK 1 - Alarm
Modbus fan 6 alarm	H419	R		0 - OK 1 - Alarm
Modbus fan 6 communication alarm	H420	R		0 - OK 1 - Alarm
Modbus fan 7 alarm	H421	R		0 - OK 1 - Alarm
Modbus fan 7 communication alarm	H422	R		0 - OK 1 - Alarm
Modbus fan 8 alarm	H423	R		0 - OK 1 - Alarm
Modbus fan 8 communication alarm	H424	R		0 - OK 1 - Alarm
Modbus fan 9 alarm	H425	R		0 - OK 1 - Alarm
Modbus fan 9 communication alarm	H426	R		0 - OK 1 - Alarm
Modbus fan 10 alarm	H427	R		0 - OK 1 - Alarm
Modbus fan 10 communication alarm	H428	R		0 - OK 1 - Alarm
Modbus fan 11 alarm	H429	R		0 - OK 1 - Alarm
Modbus fan 11 communication alarm	H430	R		0 - OK 1 - Alarm
Modbus fan 12 alarm	H431	R		0 - OK 1 - Alarm
Modbus fan 12 communication alarm	H432	R		0 - OK 1 - Alarm
Superheat setpoint circuit 1 from Carel Evd	H433	R		0 - OK 1 - Alarm
St-up opening setpoint circuit 1 from Carel Evd	H434	R		0 - OK 1 - Alarm
Evaporating pressure circuit 1 from Carel Evd	H435	R		0 - OK 1 - Alarm
Suction gas temperature circuit 1 from Carel Evd	H436	R		0 - OK 1 - Alarm
Actual superheat circuit 1 from Carel Evd	H437	R		0 - OK 1 - Alarm
Actual opening of eev circuit 1 from Carel Evd	H438	R		0 - OK 1 - Alarm
Evaporating temperature circuit 1 from Carel Evd	H439	R		0 - OK 1 - Alarm
Evaporation pressure sensor from EVD circuit 1	H440	R		0 - OK 1 - Alarm
Suctiong gas temp. sensor from EVD circuit 1	H441	R		0 - OK 1 - Alarm
MOP alarm from EVD circuit 1	H442	R		0 - OK 1 - Alarm
LOP alarm from EVD circuit 1	H443	R		0 - OK 1 - Alarm
Low superheat alarm from EVD circuit 1	H444	R		0 - OK 1 - Alarm
Expansion valve alarm from EVD circuit 1	H445	R		0 - OK 1 - Alarm
Carel EVD communication error circuit 1	H446	R		0 - OK 1 - Alarm
MVL value circuit 1	H447	R		0 - OK 1 - Alarm
MVL alarm circuit 1	H448	R		0 - OK 1 - Alarm
MVL feedback value circuit 1	H449	R		0 - OK 1 - Alarm
MVL feedback alarm circuit 1	H450	R		0 - OK 1 - Alarm
SH filtered value	H451	R		0 - OK 1 - Alarm
SH filtered alarm	H452	R		0 - OK 1 - Alarm
Circuit 2 parameters				
Condensing pressure value	H500	R	0.1	
Condensing pressure alarm	H501	R		0 - OK 1 - Alarm
Evaporating pressure value	H502	R	0.1	

Evaporating pressure alarm	H503	R		0 - OK 1 - Alarm
High pressure alarm	H504	R		0 - OK 1 - Alarm
High pressure alarm counter alarm	H505	R		0 - OK 1 - Alarm
Low pressure alarm	H506	R		0 - OK 1 - Alarm
Low pressure alarm counter alarm	H507	R		0 - OK 1 - Alarm
Conensing max pressure	H508	R		0 - OK 1 - Alarm
Conensing min pressure	H509	R		0 - OK 1 - Alarm
MOP alarm	H510	R		0 - OK 1 - Alarm
MOP counter alarm	H511	R		0 - OK 1 - Alarm
LOP alarm	H512	R		0 - OK 1 - Alarm
LOP counter alarm	H513	R		0 - OK 1 - Alarm
Pressure ratio max alarm	H514	R		0 - OK 1 - Alarm
Pressure ratio min alarm	H515	R		0 - OK 1 - Alarm
Evaporating temperature	H516	R	0.1	
Condensing tempertature	H517	R	0.1	
Circuit 2 supply temp. value	H518	R	0.1	
Circuit 2 supply temp. sensor alarm	H519	R		0 - OK 1 - Alarm
Suction temperature value	H520	R	0.1	
Suction temperature sensor fault	H521	R		0 - OK 1 - Alarm
Superheat value	H522	R	0.1	
Superheat alarm	H523	R		0 - OK 1 - Alarm
Superheat alarm counter alarm	H524	R		0 - OK 1 - Alarm
Expansion valve value	H525	R		
Expansion valve alarm	H526	R		0 - OK 1 - Alarm
Circuit 2 frost waring	H527	R		0 - OK 1 - Alarm
Circuit 2 frost alarm	H528	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT104'	H529	R	0.1	
0x2203 'Itf\Pdc.TT104'	H530	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT102'	H531	R	0.1	
0x2203 'Itf\Pdc.TT102'	H532	R		0 - OK 1 - Alarm
Defrost end temp. 1 value	H533	R	0.1	
Defrost end temp. 1 sensor alarm	H534	R		0 - OK 1 - Alarm
Defrost end temp. 2 value	H535	R	0.1	
Defrost end temp. 2 sensor alarm	H536	R		0 - OK 1 - Alarm
Defrost heater	H537	R		0 - Off 1 - On
Reverse valve	H538	R		0 - Off 1 - On
High dicharger gas temp. warning	H539	R		0 - OK 1 - Alarm
High dicharger gas temp. alarm	H540	R		0 - OK 1 - Alarm
Common discharge gas temp.	H541	R	0.1	
Common discharge gas temp. sensor alarm	H542	R		
Low evaporating temp. alarm	H543	R		0 - OK 1 - Alarm
Low evaporating pressure alarm	H544	R		0 - OK 1 - Alarm
High condensing pressure alarm	H545	R		0 - OK 1 - Alarm
No compressor is available alarm	H546	R		0 - OK 1 - Alarm
All compressor in alarm	H547	R		0 - OK 1 - Alarm
Compressor 1 fault	H548	R		0 - OK 1 - Alarm
Compressor 1 possition	H549	R		
Compressor 1 fault counter alarm	H550	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 value	H551	R	0.1	

Discharge temp. comp. 1 alarm	H552	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 alarm	H553	R		0 - OK 1 - Alarm
Suct. temp. comp. 1 value	H554	R	0.1	
Suct. temp. comp. 1 alarm	H555	R		0 - OK 1 - Alarm
Superheat temp. comp. 1 value	H556	R	0.1	
Superheat temp. comp. 1 alarm	H557	R		0 - OK 1 - Alarm
Compressor 2 fault	H558	R		0 - OK 1 - Alarm
Compressor 2 fault counter alarm	H559	R		0 - OK 1 - Alarm
Discharge temp. comp. 2 value	H560	R	0.1	
Discharge temp. comp. 2 alarm	H561	R		0 - OK 1 - Alarm
Discharge temp. comp. 2 alarm	H562	R		0 - OK 1 - Alarm
Suct. temp. comp. 2 value	H563	R	0.1	
Suct. temp. comp. 2 alarm	H564	R		0 - OK 1 - Alarm
Superheat temp. comp. 2 value	H565	R	0.1	
Superheat temp. comp. 2 alarm	H566	R		0 - OK 1 - Alarm
Compressor 3 fault	H567	R		0 - OK 1 - Alarm
Compressor 3 fault counter alarm	H568	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 value	H569	R	0.1	
Discharge temp. comp. 3 alarm	H570	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 alarm	H571	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 value	H572	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 alarm	H573	R	0.1	
Superheat temp. comp. 3 value	H574	R	0.1	
Superheat temp. comp. 3 alarm	H575	R		0 - OK 1 - Alarm
Compressor 1 status	H576	R		1 - Off 2 - On
Compressor 1 work hours	H577	R		
Compressor 1 start up counter alarm	H578	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter alarm	H579	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter feedback alarm	H580	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter comm alarm alarm	H581	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter feedback alarm	H582	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter alarm	H583	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter comm alarm alarm	H584	R		0 - OK 1 - Alarm
Compressor 2 status	H585	R		1 - Off 2 - On
Compressor 2 work hours	H586	R		
Compressor 2 start up counter alarm	H587	R		0 - OK 1 - Alarm
Compressor 3 status	H588	R		1 - Off 2 - On
Compressor 3 work hours	H589	R		
Compressor 2 start up counter alarm	H590	R		0 - OK 1 - Alarm
Condenser position	H591	R		0 - OK 1 - Alarm
Fan overload	H592	R		0 - OK 1 - Alarm
Evap. low temp. alarm counter	H593	R		0 - OK 1 - Alarm
Suction low pressure counter	H594	R		0 - OK 1 - Alarm
Discharge high pressure counter	H595	R		0 - OK 1 - Alarm
Compressor 1 high pressure alarm	H596	R		0 - OK 1 - Alarm
Compressor 1 oil alarm	H597	R		0 - OK 1 - Alarm
Compressor 1 motor overload	H598	R		0 - OK 1 - Alarm
Compressor 1 circuit breaker alarm	H599	R		0 - OK 1 - Alarm

Compressor 1 frequency alarm	H600	R		0 - OK 1 - Alarm
Compressor 2 high pressure alarm	H601	R		0 - OK 1 - Alarm
Compressor 2 oil alarm	H602	R		0 - OK 1 - Alarm
Compressor 2 motor overload	H603	R		0 - OK 1 - Alarm
Compressor 2 circuit braker alarm	H604	R		0 - OK 1 - Alarm
Compressor 3 high pressure alarm	H605	R		0 - OK 1 - Alarm
Compressor 3 oil alarm	H606	R		0 - OK 1 - Alarm
Compressor 3 motor overload	H607	R		0 - OK 1 - Alarm
Compressor 3 circuit braker alarm	H608	R		0 - OK 1 - Alarm
Modbus fan 1 alarm	H609	R		0 - OK 1 - Alarm
Modbus fan 1 communication alarm	H610	R		0 - OK 1 - Alarm
Modbus fan 2 alarm	H611	R		0 - OK 1 - Alarm
Modbus fan 2 communication alarm	H612	R		0 - OK 1 - Alarm
Modbus fan 3 alarm	H613	R		0 - OK 1 - Alarm
Modbus fan 3 communication alarm	H614	R		0 - OK 1 - Alarm
Modbus fan 4 alarm	H615	R		0 - OK 1 - Alarm
Modbus fan 4 communication alarm	H616	R		0 - OK 1 - Alarm
Modbus fan 5 alarm	H617	R		0 - OK 1 - Alarm
Modbus fan 5 communication alarm	H618	R		0 - OK 1 - Alarm
Modbus fan 6 alarm	H619	R		0 - OK 1 - Alarm
Modbus fan 6 communication alarm	H620	R		0 - OK 1 - Alarm
Modbus fan 7 alarm	H621	R		0 - OK 1 - Alarm
Modbus fan 7 communication alarm	H622	R		0 - OK 1 - Alarm
Modbus fan 8 alarm	H623	R		0 - OK 1 - Alarm
Modbus fan 8 communication alarm	H624	R		0 - OK 1 - Alarm
Modbus fan 9 alarm	H625	R		0 - OK 1 - Alarm
Modbus fan 9 communication alarm	H626	R		0 - OK 1 - Alarm
Modbus fan 10 alarm	H627	R		0 - OK 1 - Alarm
Modbus fan 10 communication alarm	H628	R		0 - OK 1 - Alarm
Modbus fan 11 alarm	H629	R		0 - OK 1 - Alarm
Modbus fan 11 communication alarm	H630	R		0 - OK 1 - Alarm
Modbus fan 12 alarm	H631	R		0 - OK 1 - Alarm
Modbus fan 12 communication alarm	H632	R		0 - OK 1 - Alarm
Superheat setpoint circuit 2 from Carel Evd	H633	R		0 - OK 1 - Alarm
St-up opening setpoint circuit 2 from Carel Evd	H634	R		0 - OK 1 - Alarm
Evaporating pressure circuit 2 from Carel Evd	H635	R		0 - OK 1 - Alarm
Suction gas temperature circuit 2 from Carel Evd	H636	R		0 - OK 1 - Alarm
Actual superheat circuit 2 from Carel Evd	H637	R		0 - OK 1 - Alarm
Actual opening of eev circuit 2 from Carel Evd	H638	R		0 - OK 1 - Alarm
Evaporating temperature circuit 2 from Carel Evd	H639	R		0 - OK 1 - Alarm
Evaporation pressure sensor from EVD circuit 2	H640	R		0 - OK 1 - Alarm
Suctiong gas temp. sensor from EVD circuit 2	H641	R		0 - OK 1 - Alarm
MOP alarm from EVD circuit 2	H642	R		0 - OK 1 - Alarm
LOP alarm from EVD circuit 2	H643	R		0 - OK 1 - Alarm
Low superheat alarm from EVD circuit 2	H644	R		0 - OK 1 - Alarm
Expansion valve alarm from EVD circuit 2	H645	R		0 - OK 1 - Alarm
Carel EVD communication error circuit 2	H646	R		0 - OK 1 - Alarm
MVL value circuit 2	H647	R		0 - OK 1 - Alarm
MVL alarm circuit 2	H648	R		0 - OK 1 - Alarm

MVL feedback value circuit 2	H649	R		0 - OK 1 - Alarm
MVL feedback alarm circuit 2	H650	R		0 - OK 1 - Alarm
SH filtered value	H651	R		0 - OK 1 - Alarm
SH filtered alarm	H652	R		0 - OK 1 - Alarm
Circuit 3 parameters				
Condensing pressure value	H700	R	0.1	
Condensing pressure alarm	H701	R		0 - OK 1 - Alarm
Evaporating pressure value	H702	R	0.1	
Evaporating pressure alarm	H703	R		0 - OK 1 - Alarm
High pressure alarm	H704	R		0 - OK 1 - Alarm
High pressure alarm counter alarm	H705	R		0 - OK 1 - Alarm
Low pressure alarm	H706	R		0 - OK 1 - Alarm
Low pressure alarm counter alarm	H707	R		0 - OK 1 - Alarm
Conensing max pressure	H708	R		0 - OK 1 - Alarm
Conensing min pressure	H709	R		0 - OK 1 - Alarm
MOP alarm	H710	R		0 - OK 1 - Alarm
MOP counter alarm	H711	R		0 - OK 1 - Alarm
LOP alarm	H712	R		0 - OK 1 - Alarm
LOP counter alarm	H713	R		0 - OK 1 - Alarm
Pressure ratio max alarm	H714	R		0 - OK 1 - Alarm
Pressure ratio min alarm	H715	R		0 - OK 1 - Alarm
Evaporating temperature	H716	R	0.1	
Condensing tempertature	H717	R	0.1	
Circuit 2 supply temp. value	H718	R	0.1	
Circuit 2 supply temp. sensor alarm	H719	R		0 - OK 1 - Alarm
Suction temperature value	H720	R	0.1	
Suction temperature sensor fault	H721	R		0 - OK 1 - Alarm
Superheat value	H722	R	0.1	
Superheat alarm	H723	R		0 - OK 1 - Alarm
Superheat alarm counter alarm	H724	R		0 - OK 1 - Alarm
Expansion valve value	H725	R		
Expansion valve alarm	H726	R		0 - OK 1 - Alarm
Circuit 2 frost waring	H727	R		0 - OK 1 - Alarm
Circuit 2 frost alarm	H728	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT104'	H729	R	0.1	
0x2203 'Itf\Pdc.TT104'	H730	R		0 - OK 1 - Alarm
0x2203 'Itf\Pdc.TT102'	H731	R	0.1	
0x2203 'Itf\Pdc.TT102'	H732	R		0 - OK 1 - Alarm
Defrost end temp. 1 value	H733	R	0.1	
Defrost end temp. 1 sensor alarm	H734	R		0 - OK 1 - Alarm
Defrost end temp. 2 value	H735	R	0.1	
Defrost end temp. 2 sensor alarm	H736	R		0 - OK 1 - Alarm
Defrost heater	H737	R		0 - Off 1 - On
Reverse valve	H738	R		0 - Off 1 - On
High dicharger gas temp. warning	H739	R		0 - OK 1 - Alarm
High dicharger gas temp. alarm	H740	R		0 - OK 1 - Alarm
Common discharge gas temp.	H741	R	0.1	
Common discharge gas temp. sensor alarm	H742	R		
Low evaporating temp. alarm	H743	R		0 - OK 1 - Alarm

Low evaporating pressure alarm	H744	R		0 - OK 1 - Alarm
High condensing pressure alarm	H745	R		0 - OK 1 - Alarm
No compressor is available alarm	H746	R		0 - OK 1 - Alarm
All compressor in alarm	H747	R		0 - OK 1 - Alarm
Compressor 1 fault	H748	R		0 - OK 1 - Alarm
Compressor 1 position	H749	R		
Compressor 1 fault counter alarm	H750	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 value	H751	R	0.1	
Discharge temp. comp. 1 alarm	H752	R		0 - OK 1 - Alarm
Discharge temp. comp. 1 alarm	H753	R		0 - OK 1 - Alarm
Suct. temp. comp. 1 value	H754	R	0.1	
Suct. temp. comp. 1 alarm	H755	R		0 - OK 1 - Alarm
Superheat temp. comp. 1 value	H756	R	0.1	
Superheat temp. comp. 1 alarm	H757	R		0 - OK 1 - Alarm
Compressor 2 fault	H758	R		0 - OK 1 - Alarm
Compressor 2 fault counter alarm	H759	R		0 - OK 1 - Alarm
Discharge temp. comp. 2 value	H760	R	0.1	
Discharge temp. comp. 2 alarm	H761	R		0 - OK 1 - Alarm
Discharge temp. comp. 2 alarm	H762	R		0 - OK 1 - Alarm
Suct. temp. comp. 2 value	H763	R	0.1	
Suct. temp. comp. 2 alarm	H764	R		0 - OK 1 - Alarm
Superheat temp. comp. 2 value	H765	R	0.1	
Superheat temp. comp. 2 alarm	H766	R		0 - OK 1 - Alarm
Compressor 3 fault	H767	R		0 - OK 1 - Alarm
Compressor 3 fault counter alarm	H768	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 value	H769	R	0.1	
Discharge temp. comp. 3 alarm	H770	R		0 - OK 1 - Alarm
Discharge temp. comp. 3 alarm	H771	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 value	H772	R		0 - OK 1 - Alarm
Suct. temp. comp. 3 alarm	H773	R	0.1	
Superheat temp. comp. 3 value	H774	R	0.1	
Superheat temp. comp. 3 alarm	H775	R		0 - OK 1 - Alarm
Compressor 1 status	H776	R		1 - Off 2 - On
Compressor 1 work hours	H777	R		
Compressor 1 start up counter alarm	H778	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter alarm	H779	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter feedback alarm	H780	R		0 - OK 1 - Alarm
Compressor 1 Vacon freq. inverter comm alarm alarm	H781	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter feedback alarm	H782	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter alarm	H783	R		0 - OK 1 - Alarm
Compressor 1 ABB freq. inverter comm alarm alarm	H784	R		0 - OK 1 - Alarm
Compressor 2 status	H785	R		1 - Off 2 - On
Compressor 2 work hours	H786	R		
Compressor 2 start up counter alarm	H787	R		0 - OK 1 - Alarm
Compressor 3 status	H788	R		1 - Off 2 - On
Compressor 3 work hours	H789	R		
Compressor 2 start up counter alarm	H790	R		0 - OK 1 - Alarm
Condenser position	H791	R		0 - OK 1 - Alarm

Fan overload	H792	R		0 - OK 1 - Alarm
Evap. low temp. alarm counter	H793	R		0 - OK 1 - Alarm
Suction low pressure counter	H794	R		0 - OK 1 - Alarm
Discharge high pressure counter	H795	R		0 - OK 1 - Alarm
Compressor 1 high pressure alarm	H796	R		0 - OK 1 - Alarm
Compressor 1 oil alarm	H797	R		0 - OK 1 - Alarm
Compressor 1 motor overload	H798	R		0 - OK 1 - Alarm
Compressor 1 circuit braker alarm	H799	R		0 - OK 1 - Alarm
Compressor 1 frequency alarm	H800	R		0 - OK 1 - Alarm
Compressor 2 high pressure alarm	H801	R		0 - OK 1 - Alarm
Compressor 2 oil alarm	H802	R		0 - OK 1 - Alarm
Compressor 2 motor overload	H803	R		0 - OK 1 - Alarm
Compressor 2 circuit braker alarm	H804	R		0 - OK 1 - Alarm
Compressor 3 high pressure alarm	H805	R		0 - OK 1 - Alarm
Compressor 3 oil alarm	H806	R		0 - OK 1 - Alarm
Compressor 3 motor overload	H807	R		0 - OK 1 - Alarm
Compressor 3 circuit braker alarm	H808	R		0 - OK 1 - Alarm
Modbus fan 1 alarm	H809	R		0 - OK 1 - Alarm
Modbus fan 1 communication alarm	H810	R		0 - OK 1 - Alarm
Modbus fan 2 alarm	H811	R		0 - OK 1 - Alarm
Modbus fan 2 communication alarm	H812	R		0 - OK 1 - Alarm
Modbus fan 3 alarm	H813	R		0 - OK 1 - Alarm
Modbus fan 3 communication alarm	H814	R		0 - OK 1 - Alarm
Modbus fan 4 alarm	H815	R		0 - OK 1 - Alarm
Modbus fan 4 communication alarm	H816	R		0 - OK 1 - Alarm
Modbus fan 5 alarm	H817	R		0 - OK 1 - Alarm
Modbus fan 5 communication alarm	H818	R		0 - OK 1 - Alarm
Modbus fan 6 alarm	H819	R		0 - OK 1 - Alarm
Modbus fan 6 communication alarm	H820	R		0 - OK 1 - Alarm
Modbus fan 7 alarm	H821	R		0 - OK 1 - Alarm
Modbus fan 7 communication alarm	H822	R		0 - OK 1 - Alarm
Modbus fan 8 alarm	H823	R		0 - OK 1 - Alarm
Modbus fan 8 communication alarm	H824	R		0 - OK 1 - Alarm
Modbus fan 9 alarm	H825	R		0 - OK 1 - Alarm
Modbus fan 9 communication alarm	H826	R		0 - OK 1 - Alarm
Modbus fan 10 alarm	H827	R		0 - OK 1 - Alarm
Modbus fan 10 communication alarm	H828	R		0 - OK 1 - Alarm
Modbus fan 11 alarm	H829	R		0 - OK 1 - Alarm
Modbus fan 11 communication alarm	H830	R		0 - OK 1 - Alarm
Modbus fan 12 alarm	H831	R		0 - OK 1 - Alarm
Modbus fan 12 communication alarm	H832	R		0 - OK 1 - Alarm
Superheat setpoint circuit 3 from Carel Evd	H833	R		0 - OK 1 - Alarm
St-up opening setpoint circuit 3 from Carel Evd	H834	R		0 - OK 1 - Alarm
Evaporating pressure circuit 3 from Carel Evd	H835	R		0 - OK 1 - Alarm
Suction gas temperature circuit 3 from Carel Evd	H836	R		0 - OK 1 - Alarm
Actual superheat circuit 3 from Carel Evd	H837	R		0 - OK 1 - Alarm
Actual opening of eev circuit 3 from Carel Evd	H838	R		0 - OK 1 - Alarm
Evaporating temperature circuit 3 from Carel Evd	H839	R		0 - OK 1 - Alarm
Evaporation pressure sensor from EVD circuit 3	H840	R		0 - OK 1 - Alarm

Suctiong gas temp. sensor from EVD circuit 3	H841	R		0 - OK 1 - Alarm
MOP alarm from EVD circuit 3	H842	R		0 - OK 1 - Alarm
LOP alarm from EVD circuit 3	H843	R		0 - OK 1 - Alarm
Low superheat alarm from EVD circuit 3	H844	R		0 - OK 1 - Alarm
Expansion valve alarm from EVD circuit 3	H845	R		0 - OK 1 - Alarm
Carel EVD communication error circuit 3	H846	R		0 - OK 1 - Alarm
Free Cooling				
Outside temp. value	H900	R	0.1	
Outside temp. sensor fault	H901	R		0 - OK 1 - Alarm
Free Cooling outlet temp. value	H902	R	0.1	
Free Cooling outlet temp. alarm	H903	R		0 - OK 1 - Alarm
Free Cooling temp. value	H904	R	0.1	
Free Cooling temp. alarm	H905	R		0 - OK 1 - Alarm
Free Cooling fail alarm	H906	R		0 - OK 1 - Alarm
Free Cooling fail counter alarm	H907	R		0 - OK 1 - Alarm
Free Cooling valve position	H908	R		
Free Cooling state	H909	R		0 - Off 1 - On
Water/Water unit Condenser				
Supply t. cond. value	H1000	R	0.1	
Supply t. cond. sensor fault	H1001	R		0 - OK 1 - Alarm
Return t. cond. value	H1002	R	0.1	
Return t. cond. sensor fault	H1003	R		0 - OK 1 - Alarm
Pump condenser status	H1004	R		0 - Off 1 - On
Fault pump condenser	H1005	R		0 - OK 1 - Alarm
Pump cond. flow det. status	H1006	R		0 - Off 1 - On
Pump cond. flow det. alarm	H1007	R		0 - OK 1 - Alarm
Cond. valve	H1008	R		

4 BACnet

Enable BACnet in Main menu -> System -> Communic. Config select BACnet over MS/TP (T6 connector) or BACnet over IP (T-IP connector).

BACnet settings are in Main menu -> System -> Communications -> BACnet. For MS/TP set correct address.

Object	Member ID	Description
Operation mode		
0x2302 'Cmn\OpModHMI'	OpMModHMI=20000	Operation mode HMI
0x230B 'Cmn\CmnOpMod'	CmnOpMod=20001	Common operation mode
0x2204 'Itf\Cmn.RemOn'	RemOn=20002	Remote On/Off
0x2302 'Cmn\OpModHMIEmgOff'	OpModHMIEmgOff=20003	Emergency off
0x2301 'Cmn\CapCtlSet.TRt'	CapCtlSetTRt=20004	Cooling setpoint return
0x2203 'Itf\Cmn.TOa'	TOa=20005	Outdoor temp.
0x2207 'Itf\Cmn.Alarm'	Alarm=20006	Alarm output
0x2204 'Itf\Cmn.GasAlarm'	GasAlarm=20007	Gas leak alarm
Dispatcher		
0x2203 'Itf\Dsp.TFI'	DspTFI=21000	Supply temperature value
0x2203 'Itf\Dsp.TRt'	DspTRt=21001	Return temperature value
0x2207 'Itf\Dsp.SuPuTwin.Cmd1'	DspSuPuTwin.Cmd1=21002	Twin pump 1 status
0x2207 'Itf\Dsp.SuPuTwin.Cmd2'	DspSuPuTwin.Cmd2=21003	Twin pump 2 status
0x2204 'Itf\Dsp.FltSuPu'	DspFltSuPu=21004	Supply pump\Twin pump 1 alarm
0x2204 'Itf\Dsp.FltSuPu2'	DspFltSuPu2=21005	Twin pump 2 alarm
0x2204 'Itf\Dsp.FIDet'	DspFIDet=21006	Supply pump flow status
0x2204 'Itf\Dsp.FIDetTwinPu'	DspFIDetTwin=21007	Twin pump flow status
0x2204 'Itf\Dsp.FIDetTwinPu.Cmd1'	DspFIDetTwinCmd1=21008	Twin pump flow status
0x2204 'Itf\Dsp.FIDetTwinPu.Cmd2'	DspFIDetTwinCmd2=21009	Twin pump flow alarm
0x2204 'Itf\Dsp.FrPrtWarn'	DspFrPrtWarn=21010	Frost waring
0x2204 'Itf\Dsp.FrPrt'	DspFrPrt=21011	Frost alarm
0x2207 'Itf\Dsp.SuPu'	DspSuPu=21012	Supply pump
Circuit 1		
0x2203 'Itf\Pdc.PCdn'	PdcPCnd=22000	Condensing pressure
0x2203 'Itf\Pdc.PEvp'	PdcPEvp=22001	Evaporating pressure
0x2204 'Itf\Pdc.HPDet'	PdcHPDet=22002	High pressure switch
0x2200 'Itf\Pdc.HPDet(Cnt)'	PdcHPDetCnt=22003	High pressure switch counter
0x2204 'Itf\Pdc.LPDet'	PdcLPDet=22004	Low pressure switch
0x2200 'Itf\Pdc.LPDet(Cnt)'	PdcLPDetCnt=22005	Low pressure switch counter
0x2204 'Itf\Pdc.HPmax'	PdcHPmax=22006	Condensing max pressure
0x2204 'Itf\Pdc.HPmin'	PdcHPmin=22007	Condensing min pressure
0x2204 'Itf\Pdc.MOP'	PdcMOP=22008	MOP alarm
0x2200 'Itf\Pdc.MOP(Cnt)'	PdcMOPCnt=22009	MOP alarm counter
0x2204 'Itf\Pdc.LOP'	PdcLOP=22010	LOP alarm
0x2200 'Itf\Pdc.LOP(Cnt)'	PdcLOPCnt=22011	LOP alarm counter
0x2204 'Itf\Pdc.PRmax'	PdcPRmax=22012	Pressure ratio max alarm

0x2204 'Itf\Pdc.PRmin'	PdcPRmin=22013	Pressure ratio min alarm
0x2203 'Itf\Pdc.TEvp'	PdcTEvp=22014	Evaporating temperature
0x2203 'Itf\Pdc.TCdn'	PdcTCnd=22015	Condensing temperature
0x2203 'Itf\Pdc.SH'	PdcSH=22016	Superheat value
0x2206 'Itf\Pdc.EEV'	PdcEEV=22017	Expansion valve value
0x2204 'Itf\Pdc.NoCprAvl'	PdcNoCprAvl=22018	No compressor is available alarm
0x2204 'Itf\Pdc.AllCprAlm'	PdcAllCprAlm=22019	All compressor in alarm
0x2208 'Itf\Pdc.CmdCpr1'	PdcCmdCpr1=22020	Compressor 1 status
0x2204 'Itf\Pdc.FltCpr1'	PdcFltCpr1=22021	Compressor 1 fault
0x2208 'Itf\Pdc.CmdCpr2'	PdcCmdCpr2=22022	Compressor 2 status
0x2204 'Itf\Pdc.FltCpr2'	PdcFltCpr2=22023	Compressor 2 fault
0x2208 'Itf\Pdc.CmdCpr3'	PdcCmdCpr3=22024	Compressor 3 status
0x2204 'Itf\Pdc.FltCpr3'	PdcFltCpr3=22025	Compressor 3 fault
0x2206 'Itf\Pdc.SrcFanPos'	PdcSrcFanPos=22026	Condenser position
0x2207 'Itf\Pdc.SrcFan'	PdcSrcFan1=22027	Fan 1 status
0x2207 'Itf\Pdc.SrcFan2'	PdcSrcFan2=22028	Fan 2 status
0x2204 'Itf\Pdc.FltSrcFan'	PdcFltSrcFan=22029	Fan overload
0x2203 'Itf\Pdc.TFI'	PdcTFI=22030	Supply temp.
0x2203 'Itf\Pdc.TDcrgCpr1'	PdcTDcrgCpr1=22031	Discharge gas comp. 1
0x2204 'Itf\Pdc.TDcrgAlrmCpr1'	PdcTDcrgAlrmCpr1=22032	Discharge gas comp. 1 alarm
0x2203 'Itf\Pdc.TSuctR290Cpr1'	PdcTSuctR290Cpr1=22033	Suct. Gas temp. comp. 1
0x2203 'Itf\Pdc.SHR290Cpr1'	PdcSHR290Cpr1=22034	Superheat comp. 1
0x2203 'Itf\Pdc.TDcrgCpr2'	PdcTDcrgCpr2=22035	Discharge gas comp. 2
0x2204 'Itf\Pdc.TDcrgAlrmCpr2'	PdcTDcrgAlrmCpr2=22036	Discharge gas comp. 2 alarm
0x2203 'Itf\Pdc.TSuctR290Cpr2'	PdcTSuctR290Cpr2=22037	Suct. Gas temp. comp. 2
0x2203 'Itf\Pdc.SHR290Cpr2'	PdcSHR290Cpr2=22038	Superheat comp. 2
0x2203 'Itf\Pdc.TDcrgCpr3'	PdcTDcrgCpr3=22039	Discharge gas comp. 3
0x2204 'Itf\Pdc.TDcrgAlrmCpr3'	PdcTDcrgAlrmCpr3=22040	Discharge gas comp. 3 alarm
0x2203 'Itf\Pdc.TSuctR290Cpr3'	PdcTSuctR290Cpr3=22041	Suct. Gas temp. comp. 3
0x2203 'Itf\Pdc.SHR290Cpr3'	PdcSHR290Cpr3=22042	Superheat comp. 3
0x2204 'Itf\Pdc.SuctLP'	PdcSuctLP=22043	Suction gas alarm
0x2204 'Itf\Pdc.DschHP'	PdcDschHP=22044	Discharge gas alarm
0x2204 'Itf\Pdc.FcAlCpr1'	PdcFcAlCpr1=22045	Vacon FC alarm
0x2204 'Itf\Pdc.FcAlFBCpr1'	PdcFcAlFBCpr1=22046	Vacon FC feedback alarm
0x2204 'Itf\Pdc.FcAlComCpr1'	PdcFcAlComCpr1=22047	Vacon FC communication alarm
0x2204 'Itf\Pdc.AbbFcAlFBCpr1'	PdcAbbFcAlFBCpr1=22048	ABB FC alarm
0x2204 'Itf\Pdc.AbbFcAlCpr1'	PdcAbbFcAlCpr1=22049	ABB FC feedback alarm
0x2204 'Itf\Pdc.AbbFcAlComCpr1'	PdcAbbFcAlComCpr1=22050	ABB FC communication alarm
0x2203 'Itf\Pdc.TSuct'	PdcTSuct=22051	Suct. Gas temp.
0x2200 'Itf\Pdc.SH(Cnt)'	PdcSHCnt=22052	Superheat alarm counter
0x2200 'Itf\Pdc.SuctLP(Cnt)'	PdcSuctLP(Cnt)=22053	Suction gas alarm counter
0x2200 'Itf\Pdc.DschHP(Cnt)'	PdcDschHP(Cnt)=22054	Discharge gas alarm counter
0x2200 'Itf\Pdc.Flt(Cnt)Cpr1'	PdcFlt(Cnt)Cpr1=22055	Compressor 1 fault counter
0x2200 'Itf\Pdc.Flt(Cnt)Cpr2'	PdcFlt(Cnt)Cpr2=22056	Compressor 2 fault counter
0x230A 'Itf\Pdc.VcnFC1Cur'	PdcVcnFC1Cur=22057	Vacon current
0x230A 'Itf\Pdc.VcnFC1Temp'	PdcVcnFC1Temp=22058	Vacon temp.
0x2200 'Itf\Pdc.RsttCntCpr1'	PdcRsttCntCpr1=22059	Start up comp.1 counter alarm
0x2200 'Itf\Pdc.RsttCntCpr2'	PdcRsttCntCpr2=22060	Start up comp.2 counter alarm
0x230A 'Itf\Itf.A_SH_R'	ASHR=22061	Superheat setpoint read

0x230A 'Itf\Itf.A_ST_OP_R'	ASTOPR=22062	St-up opening setpoint read
0x230A 'Itf\Itf.S1'	S1=22063	Evap. press. Circuit 1
0x230A 'Itf\Itf.S2'	S2=22064	Suction gas temp. Circuit 1
0x230A 'Itf\Itf.A_SH_AC'	ASHAC=22065	Actual superheat Circuit 1
0x230A 'Itf\Itf.A_EEV_OP'	AEEVOP=22066	Exp.valve Circuit 1
0x230A 'Itf\Itf.A_TEvp'	ATEvp=22067	Evaporator temp. Circuit 1
0x2204 'Itf\Cmn.Probe_1_AL'	Probe1AL=22068	Evap.press alarm Circuit 1
0x2204 'Itf\Cmn.Probe_2_AL'	Probe2AL=22069	Suction gas temp. alarm Circuit 1
0x2204 'Itf\Pdc.MOP_AL'	MOPAL=22070	MOP alarm Circuit 1
0x2204 'Itf\Pdc.LOP_AL'	LOPAL=22071	LOP alarm Circuit 1
0x2204 'Itf\Pdc.LOWSH_AL'	LOWSHAL=22072	Superheat alarm Circuit 1
0x2204 'Itf\Pdc.EEV_AL'	EEVAL=22073	Exp. Valve alarm Circuit 1
0x2204 'Itf\Pdc.AL_Evd_Com'	ALEvdCom=22074	Evd comm. error
0x2204 'Itf\Pdc.FcAlCpr1'	FcAlCpr1=22076	Frequency inverter Comp. 1 alarm
0x2204 'Itf\Pdc.FcAlComCpr1'	FcAlComCpr1=22077	Frequency inverter Comp. 1 modbus communication alarm
0x2204 'Itf\Pdc.FcAlFBCpr1'	FcAlFBCpr1=22078	Frequency inverter Comp. 1 feedback alarm
Circuit 2		
0x2203 'Itf\Pdc2.PCdn'	Pdc2PCnd=23000	Condensing pressure
0x2203 'Itf\Pdc2.PEvp'	Pdc2PEvp=23001	Evaporating pressure
0x2204 'Itf\Pdc2.HPDet'	Pdc2HPDet=23002	High pressure switch
0x2200 'Itf\Pdc2.HPDet(Cnt)'	Pdc2HPDetCnt=23003	High pressure switch counter
0x2204 'Itf\Pdc2.LPDet'	Pdc2LPDet=23004	Low pressure switch
0x2200 'Itf\Pdc2.LPDet(Cnt)'	Pdc2LPDetCnt=23005	Low pressure switch counter
0x2204 'Itf\Pdc2.HPmax'	Pdc2HPmax=23006	Condensing max pressure
0x2204 'Itf\Pdc2.HPmin'	Pdc2HPmin=23007	Condensing min pressure
0x2204 'Itf\Pdc2.MOP'	Pdc2MOP=23008	MOP alarm
0x2200 'Itf\Pdc2.MOP(Cnt)'	Pdc2MOPCnt=23009	MOP alarm counter
0x2204 'Itf\Pdc2.LOP'	Pdc2LOP=23010	LOP alarm
0x2200 'Itf\Pdc2.LOP(Cnt)'	Pdc2LOPCnt=23011	LOP alarm counter
0x2204 'Itf\Pdc2.PRmax'	Pdc2PRmax=23012	Pressure ratio max alarm
0x2204 'Itf\Pdc2.PRmin'	Pdc2PRmin=23013	Pressure ratio min alarm
0x2203 'Itf\Pdc2.TEvp'	Pdc2TEvp=23014	Evaporating temperature
0x2203 'Itf\Pdc2.TCdn'	Pdc2TCnd=23015	Condensing temperature
0x2203 'Itf\Pdc2.SH'	Pdc2SH=23016	Superheat value
0x2206 'Itf\Pdc2.EEV'	Pdc2EEV=23017	Expansion valve value
0x2204 'Itf\Pdc2.NoCprAvl'	Pdc2NoCprAvl=23018	No compressor is available alarm
0x2204 'Itf\Pdc2.AllCprAlm'	Pdc2AllCprAlm=23019	All compressor in alarm
0x2208 'Itf\Pdc2.CmdCpr1'	Pdc2CmdCpr1=23020	Compressor 1 status
0x2204 'Itf\Pdc2.FltCpr1'	Pdc2FltCpr1=23021	Compressor 1 fault
0x2208 'Itf\Pdc2.CmdCpr2'	Pdc2CmdCpr2=23022	Compressor 2 status
0x2204 'Itf\Pdc2.FltCpr2'	Pdc2FltCpr2=23023	Compressor 2 fault
0x2208 'Itf\Pdc2.CmdCpr3'	Pdc2CmdCpr3=23024	Compressor 3 status
0x2204 'Itf\Pdc2.FltCpr3'	Pdc2FltCpr3=23025	Compressor 3 fault
0x2206 'Itf\Pdc2.SrcFanPos'	Pdc2SrcFanPos=23026	Condenser position
0x2207 'Itf\Pdc2.SrcFan'	Pdc2SrcFan1=23027	Fan 1 status
0x2207 'Itf\Pdc2.SrcFan2'	Pdc2SrcFan2=23028	Fan 2 status

0x2204 'Itf\Pdc2.FltSrcFan'	Pdc2FltSrcFan=23029	Fan overload
0x2203 'Itf\Pdc2.TFI'	Pdc2TFI=23030	Supply temp.
0x2203 'Itf\Pdc2.TDcrgCpr1'	Pdc2TDcrgCpr1=23031	Discharge gas comp. 1
0x2204 'Itf\Pdc2.TDcrgAlrmCpr1'	Pdc2TDcrgAlrmCpr1=23032	Discharge gas comp. 1 alarm
0x2203 'Itf\Pdc2.TSuctR290Cpr1'	Pdc2TSuctR290Cpr1=23033	Suct. Gas temp. comp. 1
0x2203 'Itf\Pdc2.SHR290Cpr1'	Pdc2SHR290Cpr1=23034	Superheat comp. 1
0x2203 'Itf\Pdc2.TDcrgCpr2'	Pdc2TDcrgCpr2=23035	Discharge gas comp. 2
0x2204 'Itf\Pdc2.TDcrgAlrmCpr2'	Pdc2TDcrgAlrmCpr2=23036	Discharge gas comp. 2 alarm
0x2203 'Itf\Pdc2.TSuctR290Cpr2'	Pdc2TSuctR290Cpr2=23037	Suct. Gas temp. comp. 2
0x2203 'Itf\Pdc2.SHR290Cpr2'	Pdc2SHR290Cpr2=23038	Superheat comp. 2
0x2203 'Itf\Pdc2.TDcrgCpr3'	Pdc2TDcrgCpr3=23039	Discharge gas comp. 3
0x2204 'Itf\Pdc2.TDcrgAlrmCpr3'	Pdc2TDcrgAlrmCpr3=23040	Discharge gas comp. 3 alarm
0x2203 'Itf\Pdc2.TSuctR290Cpr3'	Pdc2TSuctR290Cpr3=23041	Suct. Gas temp. comp. 3
0x2203 'Itf\Pdc2.SHR290Cpr3'	Pdc2SHR290Cpr3=23042	Superheat comp. 3
0x2204 'Itf\Pdc2.SuctLP'	Pdc2SuctLP=23043	Suction gas alarm
0x2204 'Itf\Pdc2.DschHP'	Pdc2DschHP=23044	Discharge gas alarm
0x2204 'Itf\Pdc2.FcAlCpr1'	Pdc2FcAlCpr1=23045	Vacon FC alarm
0x2204 'Itf\Pdc2.FcAlFBCpr1'	Pdc2FcAlFBCpr1=23046	Vacon FC feedback alarm
0x2204 'Itf\Pdc2.FcAlComCpr1'	Pdc2FcAlComCpr1=23047	Vacon FC communication alarm
0x2204 'Itf\Pdc2.AbbFcAlFBCpr1'	Pdc2AbbFcAlFBCpr1=23048	ABB FC alarm
0x2204 'Itf\Pdc2.AbbFcAlCpr1'	Pdc2AbbFcAlCpr1=23049	ABB FC feedback alarm
0x2204 'Itf\Pdc2.AbbFcAlComCpr1'	Pdc2AbbFcAlComCpr1=23050	ABB FC communication alarm
0x2203 'Itf\Pdc2.TSuct'	Pdc2TSuct=22051	Suct. Gas temp.
0x2200 'Itf\Pdc2.SH(Cnt)'	Pdc2SHCnt=22052	Superheat alarm counter
Circuit 3		
0x2203 'Itf\Pdc3.PCdn'	Pdc3PCnd=24000	Condensing pressure
0x2203 'Itf\Pdc3.PEvp'	Pdc3PEvp=24001	Evaporating pressure
0x2204 'Itf\Pdc3.HPDet'	Pdc3HPDet=24002	High pressure switch
0x2200 'Itf\Pdc3.HPDet(Cnt)'	Pdc3HPDetCnt=24003	High pressure switch counter
0x2204 'Itf\Pdc3.LPDet'	Pdc3LPDet=24004	Low pressure switch
0x2200 'Itf\Pdc3.LPDet(Cnt)'	Pdc3LPDetCnt=24005	Low pressure switch counter
0x2204 'Itf\Pdc3.HPmax'	Pdc3HPmax=24006	Condensing max pressure
0x2204 'Itf\Pdc3.HPmin'	Pdc3HPmin=24007	Condensing min pressure
0x2204 'Itf\Pdc3.MOP'	Pdc3MOP=24008	MOP alarm
0x2200 'Itf\Pdc3.MOP(Cnt)'	Pdc3MOPCnt=24009	MOP alarm counter
0x2204 'Itf\Pdc3.LOP'	Pdc3LOP=24010	LOP alarm
0x2200 'Itf\Pdc3.LOP(Cnt)'	Pdc3LOPCnt=24011	LOP alarm counter
0x2204 'Itf\Pdc3.PRmax'	Pdc3PRmax=24012	Pressure ratio max alarm
0x2204 'Itf\Pdc3.PRmin'	Pdc3PRmin=24013	Pressure ratio min alarm
0x2203 'Itf\Pdc3.TEvp'	Pdc3TEvp=24014	Evaporating temperature
0x2203 'Itf\Pdc3.TCdn'	Pdc3TCnd=24015	Condensing temperature
0x2203 'Itf\Pdc3.SH'	Pdc3SH=24016	Superheat value
0x2206 'Itf\Pdc3.EEV'	Pdc3EEV=24017	Expansion valve value
0x2204 'Itf\Pdc3.NoCprAvl'	Pdc3NoCprAvl=24018	No compressor is available alarm
0x2204 'Itf\Pdc3.AllCprAlm'	Pdc3AllCprAlm=24019	All compressor in alarm
0x2208 'Itf\Pdc3.CmdCpr1'	Pdc3CmdCpr1=24020	Compressor 1 status
0x2204 'Itf\Pdc3.FltCpr1'	Pdc3FltCpr1=24021	Compressor 1 fault
0x2208 'Itf\Pdc3.CmdCpr2'	Pdc3CmdCpr2=24022	Compressor 2 status

0x2204 'Itf\Pdc3.FltCpr2'	Pdc3FltCpr2=24023	Compressor 2 fault
0x2208 'Itf\Pdc3.CmdCpr3'	Pdc3CmdCpr3=24024	Compressor 3 status
0x2204 'Itf\Pdc3.FltCpr3'	Pdc3FltCpr3=24025	Compressor 3 fault
0x2206 'Itf\Pdc3.SrcFanPos'	Pdc3SrcFanPos=24026	Condenser position
0x2207 'Itf\Pdc3.SrcFan'	Pdc3SrcFan1=24027	Fan 1 status
0x2207 'Itf\Pdc3.SrcFan2'	Pdc3SrcFan2=24028	Fan 2 status
0x2204 'Itf\Pdc3.FltSrcFan'	Pdc3FltSrcFan=24029	Fan overload
0x2203 'Itf\Pdc3.TFI'	Pdc3TFI=24030	Supply temp.
0x2203 'Itf\Pdc3.TDcrgCpr1'	Pdc3TDcrgCpr1=24031	Discharge gas comp. 1
0x2204 'Itf\Pdc3.TDcrgAlrmCpr1'	Pdc3TDcrgAlrmCpr1=24032	Discharge gas comp. 1 alarm
0x2203 'Itf\Pdc3.TSuctR290Cpr1'	Pdc3TSuctR290Cpr1=24033	Suct. Gas temp. comp. 1
0x2203 'Itf\Pdc3.SHR290Cpr1'	Pdc3SHR290Cpr1=24034	Superheat comp. 1
0x2203 'Itf\Pdc3.TDcrgCpr2'	Pdc3TDcrgCpr2=24035	Discharge gas comp. 2
0x2204 'Itf\Pdc3.TDcrgAlrmCpr2'	Pdc3TDcrgAlrmCpr2=24036	Discharge gas comp. 2 alarm
0x2203 'Itf\Pdc3.TSuctR290Cpr2'	Pdc3TSuctR290Cpr2=24037	Suct. Gas temp. comp. 2
0x2203 'Itf\Pdc3.SHR290Cpr2'	Pdc3SHR290Cpr2=24038	Superheat comp. 2
0x2203 'Itf\Pdc3.TDcrgCpr3'	Pdc3TDcrgCpr3=24039	Discharge gas comp. 3
0x2204 'Itf\Pdc3.TDcrgAlrmCpr3'	Pdc3TDcrgAlrmCpr3=24040	Discharge gas comp. 3 alarm
0x2203 'Itf\Pdc3.TSuctR290Cpr3'	Pdc3TSuctR290Cpr3=24041	Suct. Gas temp. comp. 3
0x2203 'Itf\Pdc3.SHR290Cpr3'	Pdc3SHR290Cpr3=24042	Superheat comp. 3
0x2204 'Itf\Pdc3.SuctLP'	Pdc3SuctLP=24043	Suction gas alarm
0x2204 'Itf\Pdc3.DschHP'	Pdc3DschHP=24044	Discharge gas alarm
0x2204 'Itf\Pdc3.FcAlCpr1'	Pdc3FcAlCpr1=24045	Vacon FC alarm
0x2204 'Itf\Pdc3.FcAlFBCpr1'	Pdc3FcAlFBCpr1=24046	Vacon FC feedback alarm
0x2204 'Itf\Pdc3.FcAlComCpr1'	Pdc3FcAlComCpr1=24047	Vacon FC communication alarm
0x2204 'Itf\Pdc3.AbbFcAlFBCpr1'	Pdc3AbbFcAlFBCpr1=24048	ABB FC alarm
0x2204 'Itf\Pdc3.AbbFcAlCpr1'	Pdc3AbbFcAlCpr1=24049	ABB FC feedback alarm
0x2204 'Itf\Pdc3.AbbFcAlComCpr1'	Pdc3AbbFcAlComCpr1=24050	ABB FC communication alarm
0x2203 'Itf\Pdc3.TSuct'	Pdc3TSuct=24051	Suct. Gas temp.
0x2200 'Itf\Pdc3.SH(Cnt)'	Pdc3SHCnt=24052	Superheat alarm counter
Water condenser		
0x2203 'Itf\SrcW.TFIcnd'	SrcWTFICnd=25000	Condenser supply temp. to user
0x2203 'Itf\SrcW.TRtCnd'	SrcWTRtCnd=25001	Condenser return temp. from user
0x2207 'Itf\SrcW.SuPuCnd'	SrcWSuPuCnd=25002	Condenser pump status